



2022/2023

Energy Consumption and Greenhouse Gas Emission Report

for the

THAMES VALLEY DISTRICT SCHOOL BOARD

Property Name	Operation	Address	City	Postal Code	Gross Floor Area(M ²)	Weekly Average Hours	Number of Portables	Swimming pool	Electricity Use - Grid Purchase (kWh)	Natural Gas Use (GJ)	Propane Use (GJ)	Site Energy Use (GJ)	Site EUI (GJ/m ²)	Site EUI (EkWh/m ²)	Total (Location-Based) GHG Emissions (Metric Tons CO ₂ e)	Total (Location-Based) GHG Emissions Intensity (kgCO ₂ e/m ²)	Comments
A. B. Lucas SS	School	656 Tennent AVE	LONDON	N5X1L8	14958	72	7	No	816495.9	4040.9		6980.2	0.47	130.6	226	15.1	
A. J. Baker PS	School	195910 19th Line	KINTORE	N0M2C0	1487.9	60	5	No	132327.4	783.6		1260	0.85	236.1	43.1	29.1	
Aberdeen PS	School	580 Grey ST	LONDON	N6B1H8	3845.9	60	0	No	126504.8	2403.4		2858.8	0.74	205.6	124.4	32.3	
Adelaide - W G MacDonald PS	School	29059 School RD RR 5	STRATHROY	N7G3H6	2690.9	60	0	No	219485.9	1050.9		1841	0.68	188.9	59	21.9	
Aldborough PS	School	11443 Furnival RD	RODNEY	N0L2C0	3536.6	60	0	No	221346.8	1773.4		2570.2	0.73	202.8	95.4	27	
Algonquin PS	School	59 Algonquin RD	WOODSTOCK	N4T1R8	6132.5	65	6	No	668260.7	2009.2		4414.9	0.72	200.0	119.7	19.5	
Annapdale PS	School	60 Tillson AVE	TILLSONBURG	N4G3A1	6026.3	60	0	No	356583.6	2358.9		3642.6	0.6	166.7	128.6	21.3	
Arthur Ford PS	School	617 Viscount RD	LONDON	N6J2Y4	3362.9	60	5	No	177002.7	1401		2038.2	0.62	172.2	75.4	23	
Arthur Stringer PS	School	43 SHAFTESBURY AVE	LONDON	N6C2Y5	3090	60	0	No	291294.4	1777.2		2825.8	0.91	252.8	97.5	31.6	
Arthur Voaden SS	School	41 Flora ST	ST THOMAS	N5P2X5	16341.6	60	0	No	886861.9	2039.4		5231.9	0.32	88.9	127.4	7.8	
Ashley Oaks PS	School	121 Ashley CRES	LONDON	N6E3W2	6853	65	2	No	691811.2	3414.7		5905.2	0.86	238.9	191.1	27.9	
B. Davison SS	School	785 Trafalgar ST	LONDON	N5Z1E6	8771.7	50	0	No	438503.5	5841.2		7419.8	0.85	236.1	306	34.9	
Balaclava Street Education Centre	School	20 Balaclava ST	ST THOMAS	N5P3C2	2868.9	50	0	No	31017.9	2103.6		2215.3	0.77	213.9	106.6	37.2	
Blenheim District PS	School	32 Wilmot ST N GD	DRUMBO	N0J1G0	3612	60	0	No	321323.2	470.9		1627.6	0.45	125.0	32.7	9	
Blossom Park Education Centre	School	391 Blossom park RD	WOODSTOCK	N4S7J3	848.9	50	0	No	35027.9	617.4		743.5	0.88	244.4	32	37.8	
Bonaventure Meadows PS	School	141 Bonaventure DR	LONDON	N5V4S6	6070.9	65	0	No	571677.7	1556.2		3614.2	0.6	166.7	94.2	15.5	
Byron Northview PS	School	1370 Commissioners RD W	LONDON	N6K1E1	3996.4	60	7	No	278371.5	2384		3386.1	0.85	236.1	127.7	31.9	
Byron Somerset PS	School	175 Whisperwood AVE	LONDON	N6K4C6	5773.9	65	6	No	496414	1375.5		3162.5	0.57	158.3	83.1	14.9	
Byron Southwood PS	School	1379 Lola ST	LONDON	N6K3R6	4084.8	60	1	No	230035.1	1887.9		2716	0.69	191.7	101.4	25.7	
C C. Carrothers PS	School	360 Chippendale CRES	LONDON	N5Z3G2	3742	60	0	No	186654.6	1366.3		2038.3	0.54	150.0	73.9	19.8	
Caradoc North PS	School	8041 Scotchmere DR RR 1	STRATHROY	N7G3H3	1774.9	60	2	No	171007.8	958.9		1574.5	0.85	236.1	53	28.7	
Caradoc PS	School	714 BOWAN ST E	MOUNT BRYDGES	N0L1W0	3992	60	5	No	389726	1170.9		2573.9	0.62	172.2	69.8	16.9	
Carrothers Field	School	357 Pall Mall Street	LONDON	N6B2G8	185	50	0	No	3168.6	132		143.4	0.78	216.7	6.7	36.5	Sports Field and Field house
Cedar Hollow PS	School	1800 Cedarhollow Blvd.	LONDON	N5X0K3	7334.1	65	5	No	484856.2	1113.1		2858.6	0.39	108.3	69.5	9.5	
Centennial Central PS	School	14774 Medway RD	ARVA	N0M1C0	2900.7	60	1	No	210170.1	1410.4		2167	0.75	208.3	76.8	26.5	
Central Elgin CI	School	201 Chestnut ST	ST THOMAS	N5R2B5	9190	60	0	No	653780	4111.5		6465	0.7	194.4	225	24.5	
Central PS	School	410 Hunter ST	WOODSTOCK	N4S4G4	4194.9	60	8	No	324981.6	1973.3		3143.2	0.74	205.6	108.3	25.4	

Property Name	Operation	Address	City	Postal Code	Gross Floor Area(M ²)	Weekly Average Hours	Number of Portables	Swimming pool	Electricity Use - Grid Purchase (kWh)	Natural Gas Use (GJ)	Propane Use (GJ)	Site Energy Use (GJ)	Site EUI (GJ/m ²)	Site EUI (EkWh/m ²)	Total (Location-Based) GHG Emissions (Metric Tons CO ₂ e)	Total (Location-Based) GHG Emissions Intensity (kgCO ₂ e/m ²)	Comments
Central SS	School	509 Waterloo ST	LONDON	N6B2P8	11712.9	65	0	No	1038107.4	4895		8632	0.74	205.6	275.2	23.5	
Chippewa PS	School	1035 Chippewa DR	LONDON	N5V2T6	5844.9	60	0	No	421096.7	1903.2		3419.1	0.59	163.9	107.5	18.4	
Clara Brenton PS	School	1025 St. Croix Ave.	LONDON	N6H3X8	5231.8	60	6	No	357279.5	2214.9		3501.1	0.69	191.7	121.4	23.9	
Clarke Road SS	School	300 Clarke RD	LONDON	N5W5N4	20888	65	0	No	1613784.4	6246.8		12056.2	0.58	161.1	359.3	17.2	
Cleardale PS	School	780 Dulaney DR	LONDON	N6C3W4	5371.9	60	0	No	312909.5	1855.4		2981.9	0.56	155.6	102	19	
College Avenue SS	School	700 College AVE	WOODSTOCK	N4S2C8	14809.7	60	0	No	1171282.9	7165.5		11382	0.77	213.9	393.1	26.5	
Davenport PS	School	80 Rutherford AVE	AYLMER	N5H2N8	3431.9	60	0	No	141230.4	1436.3		1944.7	0.57	158.3	76.2	22.2	
Delaware Central PS	School	14 Osborne Street	DELAWARE	N0L1E0	2408	60	1	No	123125.5	800.3		1243.6	0.52	144.4	43.7	18.1	
Dunwich-Dutton PS	School	239 Miller Road	DUTTON	N0L1J0	3930.9	60	4	No	267662	1269.9		2233.5	0.57	158.3	71.3	18.2	
Eagle Heights PS	School	284 Oxford ST W	LONDON	N6H1S9	6951.5	60	17	No	651780.7	1883.7		4230	0.61	169.4	113	16.2	
Ealing PS	School	840 Hamilton RD	LONDON	N5Z1V5	4309.8	60	0	No	120291	2344.8		2777.9	0.64	177.8	121.3	28.1	
East Carling PS	School	814 Quebec ST	LONDON	N5Y1X4	4603.9	65	1	No	342834.9	1398.8		2632.9	0.59	163.9	79.9	17.9	
East Elgin SS	School	362 Talbot ST W	AYLMER	N5H1K6	16995.2	60	1	No	902798.1	9193.4		12443.3	0.73	202.8	487.5	28.7	
East Oxford Central PS	School	505767 Old stage RD RR 4	WOODSTOCK	N4S7V8	2626	60	0	No	98845	1286.8		1642.6	0.63	175.0	67.5	25.7	
East Williams Memorial PS	School	4441 Queen St. RR 1	AILSA CRAIG	N0M1A0	2465.9	60	0	No	153203.2	1173.1		1724.6	0.7	194.4	63.3	25.7	
Eastdale PS	School	65 Aileen DR	WOODSTOCK	N4S4A2	2253	60	0	No	134170	1089.5		1572.4	0.7	194.4	58.5	26	
Education Centre	Administrative offices and related facilities	1250 Dundas ST	LONDON	N5W5P2	11842.9	65	0	No	1176624.2	3463.2		7698.9	0.65	180.6	207.1	17.5	
Ekcoe Central PS	School	3719 Parkhouse RD RR 3	GLENCOE	N0L1M0	3608	60	2	No	209081.6	1353.7		2106.4	0.58	161.1	73.9	20.5	
Elgin Court PS	School	254 First AVE	ST THOMAS	N5R4P5	3770.9	60	0	No	176522	977.8		1613.2	0.43	119.4	54.1	14.4	
Emily Carr PS	School	44 Hawthorne RD	LONDON	N6G2H5	6508.8	60	5	No	660899.5	2860.3		5239.4	0.82	227.8	162.3	25.5	
Emily Stowe PS	School	1 Jerdon ST RR 1	NORWICH	N0J1P0	5501	60	0	No	487871.3	2485.2		4241.4	0.77	213.9	138.6	25.2	
Eve Circe Cote FI PS	School	45885 Sparta LINE RR 4	ST THOMAS	N5P3S8	2505.3	60	0	No	132995	1036.3		1515.1	0.6	166.7	55.8	22.3	
Evelyn Harrison PS	School	50 Tewksbury CRES	LONDON	N5V2M8	3816.9	60	0	No	116082.2	2248.4		2666.3	0.7	194.4	116.3	30.5	
F. D. Roosevelt PS	School	560 Second ST	LONDON	N5V2B7	3625	60	0	No	202686	1767.5		2497.2	0.69	191.7	94.5	26.1	
Facility Services - Corp. & Warehouse	Administrative offices and related facilities	951 Leathorne ST	LONDON	N5Z3M7	5772.9	50	0	No	48853.9	1316.3		1492.2	0.26	72.2	67.5	11.7	CNG Fleet refueling system
Facility Services - Zone 3	Administrative offices and related facilities	745 Hounsfield ST	WOODSTOCK	N4S1P6	529.9	50	0	No	417873.5	3997.8		5502.1	10.38	2883.3	212.7	401.3	CNG Fleet refueling system
Facility Services - Zone 4	Administrative offices and related facilities	259 EDWARD ST	ST THOMAS	N5P4A9	753	50	0	No	33195.2	1848.8		1968.3	2.61	725.0	93.9	124.7	CNG Fleet refueling system

Property Name	Operation	Address	City	Postal Code	Gross Floor Area(M ²)	Weekly Average Hours	Number of Portables	Swimming pool	Electricity Use - Grid Purchase (kWh)	Natural Gas Use (GJ)	Propane Use (GJ)	Site Energy Use (GJ)	Site EUI (GJ/m ²)	Site EUI (EkWh/m ²)	Total (Location-Based) GHG Emissions (Metric Tons CO ₂ e)	Total (Location-Based) GHG Emissions Intensity (kgCO ₂ e/m ²)	Comments
Facility Services - Zone 5	Administrative offices and related facilities	14766 Medway RD	ARVA	N0M1C0	482	50	1	No	43750.7	1055.6		1213.1	2.52	700.0	54.3	112.6	CNG Fleet refueling system
Fairmont PS	School	1040 Hamilton RD	LONDON	N5W1A6	3291.9	60	0	No	45849.5	2021.6		2186.6	0.66	183.3	102.9	31.3	Closed
Forest Park PS	School	295 Forest AVE	ST THOMAS	N5R2K5	4270.9	60	0	No	248101.6	1167.3		2060.4	0.48	133.3	65.6	15.4	
Secondary School Day Programs	School	70 Jacqueline ST	LONDON	N5Z3P7	15209.9	50	0	No	711118.8	8072		10631.9	0.7	194.4	425.7	28	
Glen Cairn PS	School	53 Frontenac RD	LONDON	N5Z3Y5	7962.9	60	0	No	623718.9	2286.7		4532	0.57	158.3	132.4	16.6	
Glencoe DHS	School	3581 Concession Dr	GLENCOE	N0L1M0	7792	60	0	No	453347.3	2554.4		4186.4	0.54	150.0	141.1	18.1	
Glendale HS	School	37 Glendale DR	TILLSONBURG	N4G1J6	11643.8	60	0	No	817286.5	8826		11768.1	1.01	280.6	466.6	40.1	
H B Beal SS	School	525 Dundas ST	LONDON	N6B1W5	28664	65	3	Yes	2153934.1	6850.4		14604.2	0.51	141.7	404.7	14.1	
Harrisfield PS	School	2 Caffyn ST	INGERSOLL	N5C3M8	5403.2	60	4	No	459148.4	1556.3		3209.2	0.61	169.4	91.1	17.4	
Hickson Central PS	School	161 LOVEYS ST	HICKSON	N0J1L0	4633.9	60	7	No	288755.4	2416.1		3455.5	0.75	208.3	129.6	28	
Hillcrest PS	School	1231 Fuller ST	LONDON	N5Y4P7	3625	60	0	No	143388.8	1716		2232.1	0.62	172.2	90.3	24.9	
Huron Park SS	School	900 Cromwell ST	WOODSTOCK	N4S5B5	13684	60	0	No	677323.3	7312.9		9751.1	0.71	197.2	386.6	28.3	
Ingersoll District CI	School	37 ALMA ST	INGERSOLL	N5C1N1	17407.9	65	0	No	693929.2	8312.4		10810.4	0.62	172.2	437.3	25.1	
Innerkip Central PS	School	180 Coleman ST GD	INNERKIP	N0J1M0	2864.9	60	2	No	122266.2	1505		1945.2	0.68	188.9	79.1	27.6	
J.S. Buchanan FI PS	School	248 Keefer ST	STRATHROY	N7G1E2	2933.8	60	0	No	185787.2	1296		1964.8	0.67	186.1	70.4	24	
Jack Chambers PS	School	1650 Hastings DR	LONDON	N5X3E3	7528.1	65	1	No	610144.2	3191.2		5387.6	0.73	202.8	177.5	24.1	
Jaffa Environmental Ed. Centre	School	48436 John wise LINE RR 5	AYLMER	N5H2R4	318.9	50	1	No	33876.6	129.1		251.1	0.79	219.4	7.4	23.5	
Jeanne Sauvé FI PS	School	215 Wharncliffe RD N	LONDON	N6H2B6	4312.9	60	0	No	106512	1919.1		2302.5	0.53	147.2	99.5	23.1	
John Dearness PS	School	555 SANATORIUM RD	LONDON	N6H3W6	2354.9	60	2	No	150265.3	121.1		662.1	0.27	75.0	10.3	4.2	
John P Robarts PS	School	84 Bow ST	LONDON	N5V1B1	6395.8	60	0	No	410711.5	2092.5		3571	0.57	158.3	116.7	18.8	
John Wise PS	School	100 Parkside DR	ST THOMAS	N5R3T9	5327	60	0	No	391022.7	1273		2680.6	0.5	138.9	75	14.1	
June Rose Callwood PS	School	84 Edward ST	ST THOMAS	N5P1Y7	4223.7	60	1	No	296125.9	964.2		2030.2	0.48	133.3	56.8	13.5	
Kensal Park FI PS	School	328 Springbank DR	LONDON	N6J1G5	6190.7	60	3	No	688759	1469.8		3949.2	0.66	183.3	93.2	15.5	
Kettle Creek PS	School	350 Carlow RD	PORT STANLEY	N5L1B6	3435.9	60	6	No	217273.4	989.6		1771.7	0.5	138.9	55.8	15.6	
Knollwood Park PS	School	70 Gammage ST	LONDON	N5Y2B1	4523	60	0	No	165593.9	2641.7		3237.8	0.72	200.0	137.5	30.4	
Lambeth PS	School	6820 Duffield ST	LONDON	N6P1A4	5952.4	60	11	No	507899.3	1315.9		3144.2	0.53	147.2	80.4	13.5	
Laurie Hawkins PS	School	156 Innes ST	INGERSOLL	N5C2R8	5468.7	60	0	No	301456.1	801.2		1886.4	0.34	94.4	48.7	8.9	

Property Name	Operation	Address	City	Postal Code	Gross Floor Area(M ²)	Weekly Average Hours	Number of Portables	Swimming pool	Electricity Use - Grid Purchase (kWh)	Natural Gas Use (GJ)	Propane Use (GJ)	Site Energy Use (GJ)	Site EUI (GJ/m ²)	Site EUI (EkWh/m ²)	Total (Location-Based) GHG Emissions (Metric Tons CO ₂ e)	Total (Location-Based) GHG Emissions Intensity (kgCO ₂ e/m ²)	Comments
Lester B Pearson School for the Arts	School	795 Trafalgar ST	LONDON	N5Z1E6	4924	60	0	No	330928.1	1226.1		2417.4	0.49	136.1	70.9	14.4	
Locke's PS	School	20 South edgeware RD	ST THOMAS	N5P2H2	5640.1	60	7	No	421861.1	1516		3034.7	0.54	150.0	88	15.6	
London Env. Ed. Ctr. - Pond Mills	School	1095 POND VIEW RD	LONDON	N5Z4K2	458.9	50	0	No	37544	229.3		364.5	0.8	222.2	12.6	27.5	
London Env. Ed. Ctr. - Westminster Ponds	School	696 Wellington RD	LONDON	N6C4R2	146	50	0	No	603879.8	Not Available		2173.9	5.71	1586.1	16.9	44.4	Geothermal Heatpump
London South CI	School	371 Tecumseh AVE E	LONDON	N6C1T4	10068.9	65	1	No	465094.7	3010.9		4685.2	0.47	130.6	164.4	16.3	
Lord Dorchester SS	School	61 Queen ST	DORCHESTER	N0L1G2	8581	60	0	No	417102.8	4349.2		5850.7	0.68	188.9	230.3	26.8	
Lord Elgin PS	School	1100 Victoria DR	LONDON	N5Y4E2	3066	60	1	No	242675.4	1489.2		2362.8	0.75	208.3	81.7	26	
Lord Nelson PS	School	1990 Royal CRES	LONDON	N5V1N8	5922.5	65	0	No	166380.3	1925.7		2524.6	0.43	119.4	101.5	17.1	
Lord Roberts FI PS	School	440 Princess AVE	LONDON	N6B2B3	3845.9	60	3	No	807331.9	1737.8		4644	1.21	336.1	110	28.6	
Louise Arbour FI PS	School	365 Belfield ST	LONDON	N5Y2K3	9627	60	0	No	351023.4	1858		3121.7	0.32	88.9	103.2	10.7	
Maple Lane PS	School	25 Maple LANE	TILLSONBURG	N4G2Y8	2919.9	0	0	No	0	0		0	0	0.0	0	0	
Mary Wright PS	School	213 Carroll ST W	STRATHROY	N7G1B1	5315.5	60	0	No	400149.6	1625.5		3066	0.58	161.1	92.9	17.5	
Masonville PS	School	25 Hillview BLVD	LONDON	N6G3A7	3871.9	60	6	No	86839.6	2250.3		2562.9	0.72	200.0	115.6	32.5	
McGillivray Central PS	School	34714 Creamery RD	AILSA CRAIG	N0M1A0	1859.9	60	0	No	227228	Not Available	906	1724	0.93	258.3	61.8	33.2	
McGregor PS	School	204 John ST S	AYLMER	N5H2C8	4348	60	0	No	1312855.2	1447.7		6173.8	1.42	394.4	109.5	25.2	
Medway HS	School	14405 Medway RD	ARVA	N0M1C0	15506.3	60	0	No	405812	6102.5		7563.4	0.49	136.1	318.2	20.5	
Mitchell Hepburn PS	School	95 Raven AVE	ST THOMAS	N5R0C2	5811.1	60	2	No	1312717.2	850.3		5575.9	0.97	269.4	79.5	13.9	
Montcalm SS	School	1350 Highbury AVE N	LONDON	N5Y1B5	19038.9	60	0	No	117684.2	9913.9		10337.6	0.54	150.0	501.7	26.4	
Mosa Central PS	School	22741 Pratt siding RD RR 1	GLENCOE	N0L1M0	2033	60	0	No	250562.4	1050.3		1952.2	0.96	266.7	59.8	29.4	
Mountsfield PS	School	8 Mountsfield DR	LONDON	N6C2S4	4764.9	60	1	No	194831.3	2061.4		2762.8	0.58	161.1	109.1	22.9	
New Sarum PS	School	9473 Belmont RD RR 3	ST THOMAS	N5P3S7	3028.2	60	0	No	254313.1	1136.7		2052.2	0.68	188.9	64.3	21.2	
Nicholas Wilson PS	School	927 Osgoode DR	LONDON	N6E1C9	3086	60	0	No	587513.7	1893.9		4008.9	1.3	361.1	111.7	36.2	
North Meadows PS	School	82 Middlesex DR	STRATHROY	N7G4G5	4704	60	0	No	436202.8	3314.7		4884.9	1.04	288.9	178.9	38	
North Middlesex DHS	School	100 Main St	PARKHILL	N0M2K0	6657	60	0	No	265797.3	4142.6		5099.4	0.77	213.9	215.7	32.4	
Northbrae PS	School	335 Belfield ST	LONDON	N5Y2K3	4272.7	65	4	No	243623.9	2469.1		3346.1	0.78	216.7	131	30.7	
Northdale Central PS	School	3860 Catherine St	DORCHESTER	N0L1G0	3033.9	60	0	No	214566.7	2095.4		2867.8	0.95	263.9	111.4	36.7	
Northdale PS	School	290 Victoria ST N	WOODSTOCK	N4S6W5	2768	60	4	No	367297.8	866.7		2188.9	0.79	219.4	53.9	19.5	

Property Name	Operation	Address	City	Postal Code	Gross Floor Area(M ²)	Weekly Average Hours	Number of Portables	Swimming pool	Electricity Use - Grid Purchase (kWh)	Natural Gas Use (GJ)	Propane Use (GJ)	Site Energy Use (GJ)	Site EUI (GJ/m ²)	Site EUI (EkWh/m ²)	Total (Location-Based) GHG Emissions (Metric Tons CO2e)	Total (Location-Based) GHG Emissions Intensity (kgCO2e/m ²)	Comments
Northridge PS	School	25 Mclean DR	LONDON	N5X1Y2	5177.2	60	0	No	1102824	1357		5327	1.03	286.1	99.1	19.1	
Oakridge SS	School	1040 Oxford ST W	LONDON	N6H1V4	14522	65	1	No	272561.7	4423.9		5405.1	0.37	102.8	230.1	15.8	
Oliver Stephens PS	School	164 Fyfe AVE	WOODSTOCK	N4S3S6	3706	60	0	No	144649	1128.5		1649.2	0.45	125.0	60.8	16.4	
Orchard Park PS	School	50 Wychwood PK	LONDON	N6G1R6	2588.9	60	1	No	297024	948.6		2017.8	0.76	211.1	56	21.1	
Oxbow PS	School	13624 Ilderton RD	ILDERTON	N0M2A0	4057	60	4	No	225778.3	1099		1911.8	0.46	127.8	61.6	14.9	
P.E. Trudeau FI PS	School	112 Churchill CRES	ST THOMAS	N5R 1R1	4510.9	60	0	No	1150948	2748.1		6891.4	1.53	425.0	170.4	37.8	
Parkhill-West Williams PS	School	204 McLeod St	PARKHILL	N0M2K0	2376.9	60	0	No	245211.2	569		1451.7	0.61	169.4	35.5	14.9	
Parkside CI	School	241 Sunset DR	ST THOMAS	N5R3C2	13928.4	65	1	No	249111.8	2911.2		3808	0.27	75.0	153.3	11	
Parkview PS	School	10008 Oxbow DR	KOMOKA	N0L1R0	4376	60	1	No	172475.2	1246.2		1867.1	0.43	119.4	67.5	15.7	
Plattsville & District PS	School	112 Mill St E	PLATTSVILLE	N0J1S0	2730	65	0	No	17023.9	1144.9		1206.2	0.44	122.2	58	21.3	
Port Burwell PS	School	30 Strachan Street	PORT BURWELL	N0J1T0	2130.9	60	0	No	85272.7	660.1		967.1	0.45	125.0	35.6	16.7	
Prince Charles PS	School	1601 Wavell ST	LONDON	N5W2C9	5336.5	60	0	No	246817.4	2380.5		3269	0.61	169.4	126.6	23.7	
Princess Anne FI PS	School	191 Dawn DR	LONDON	N5W4W9	4122.6	60	2	No	160784.5	1960.6		2539.4	0.63	175.0	103.1	25.6	
Princess Elizabeth PS	School	247 Thompson RD	LONDON	N5Z2Z3	7050.5	60	3	No	324290.7	2816.2		3983.6	0.57	158.3	150.7	21.4	
Rick Hansen PS	School	70 Ponderosa CRES	LONDON	N6E2L7	4082	65	0	No	294198.2	1046.3		2105.4	0.52	144.4	60.8	14.9	
River Heights PS	School	4269 Hamilton RD	DORCHESTER	N0L1G3	3387.1	60	1	No	190252.1	2830.7		3515.6	1.04	288.9	147.6	43.6	
Riverside PS	School	550 Pinetree DR	LONDON	N6H3N1	4271.3	60	2	No	212581.1	1411.4		2176.7	0.51	141.7	76.9	18	
Roch Carrier FI PS	School	840 Sloane ST	WOODSTOCK	N4S7V3	3101.9	60	10	No	253151.3	1406.8		2318.1	0.75	208.3	77.8	25.1	
Royal Roads PS	School	210 King ST E	INGERSOLL	N5C1H2	4213.2	60	2	No	268598.1	462.1		1429	0.34	94.4	30.8	7.3	
Ryerson PS	School	940 Waterloo ST	LONDON	N6A3X3	4387	60	5	No	200788.5	2128.9		2851.7	0.64	177.8	112.7	25.3	
Saunders SS	School	941 Viscount RD	LONDON	N6K1H5	28500	70	0	No	1971158.1	9894.7		16990.6	0.6	166.7	552.7	19.4	
Sir Arthur Currie PS	School	2435 Buroak Dr.	LONDON	N6G0L1	7046	65	17	No	562406.2	1103.6		3128.2	0.44	122.2	71.2	10.1	
Sir F. Banting Annex	School	127 Sherwood forest SQ	LONDON	N6G2C3	1316	50	4	No	217945.6	388.5		1173.1	1.15	319.4	25.6	25	
Sir Frederick Banting SS	School	125 Sherwood forest SQ	LONDON	N6G2C3	19827.9	65	2	No	1296953.3	6492.1		11161	0.56	155.6	362.7	18.3	
Sir Georges Etienne Cartier PS	School	695 CHIDDINGTON AVE	LONDON	N6C2W9	2799	60	7	No	245123.3	1283.7		2166.1	0.78	216.7	71.4	25.6	
Sir Isaac Brock PS	School	80 ST LAWRENCE BLVD	LONDON	N6J2X1	3760	60	12	No	454614.1	1839.8		3476.3	0.97	269.4	105.2	29.3	
Sir John A. Macdonald PS	School	1150 Landor ST	LONDON	N5Y3W3	6077	65	0	No	245224.7	3105.5		3988.3	0.66	183.3	163	26.8	

Property Name	Operation	Address	City	Postal Code	Gross Floor Area(M ²)	Weekly Average Hours	Number of Portables	Swimming pool	Electricity Use - Grid Purchase (kWh)	Natural Gas Use (GJ)	Propane Use (GJ)	Site Energy Use (GJ)	Site EUI (GJ/m ²)	Site EUI (EkWh/m ²)	Total (Location-Based) GHG Emissions (Metric Tons CO2e)	Total (Location-Based) GHG Emissions Intensity (kgCO2e/m ²)	Comments
Sir Wilfrid Laurier SS	School	450 Millbank DR	LONDON	N6C4W7	14929	65	6	No	908459.8	3796.4		7066.7	0.47	130.6	216.3	14.5	
South Dorchester PS	School	48614 Crossely Hunter Line	BELMONT	N0L1B0	1680	60	8	No	180617.2	1370.1		2020.3	1.16	322.2	73.9	42.3	
South Ridge PS	School	10 South ridge RD	TILLSONBURG	N4G0C1	3816	60	0	No	279350.1	1292.2		2297.8	0.6	166.7	72.8	19.1	
Southside PS	School	360 Albert ST	WOODSTOCK	N4S2L4	3618.7	60	1	No	187508.5	1063.8		1738.8	0.48	133.3	58.7	16.2	
Southwold PS	School	39261 Fingal LINE RR 1	ST THOMAS	N5P3S5	5153.5	60	2	No	306075.5	1635.5		2737.3	0.53	147.2	90.8	17.6	
Springbank PS	School	1060 Sprucedale RD	WOODSTOCK	N4S4Z9	4387.9	60	6	No	353652.7	1131.6		2404.7	0.54	150.0	66.8	15	
Springfield PS	School	51336 Ron mcneil LINE GD	SPRINGFIELD	N0L2J0	2244	60	0	No	160889.6	330.9		910.1	0.41	113.9	21.1	9.4	
St. George's PS	School	782 Waterloo ST	LONDON	N6A3W4	4146	60	5	No	286290.6	1429.7		2460.3	0.59	163.9	79.9	19.3	
Stoney Creek PS	School	1335 Nicole AVE	LONDON	N5X4M7	6983	60	7	No	542937.4	1042.9		2997.4	0.43	119.4	67.6	9.7	
Stoneybrook PS	School	1460 Stoneybrook CRES	LONDON	N5X1C4	3423.9	60	4	No	351069.5	1499.7		2763.5	0.81	225.0	85.2	25	
Straffordville PS	School	9188 Plank RD GD	STRAFFORDVILLE	N0J1Y0	4161.4	60	0	No	153287.4	1727.8		2279.6	0.55	152.8	91.2	21.9	
Strathroy DCI	School	361 Second ST	STRATHROY	N7G4J8	15326.5	65	0	No	2664571.3	8646.8		18238.8	1.2	333.3	509.3	33.4	
Summers' Corners PS	School	50576 Talbot ST E RR 1	AYLMER	N5H2R1	5717.9	65	0	No	344715.1	3428.1		4669	0.82	227.8	182	31.8	
Summerside P.S.	School	2541 Meadowgate Blvd	London	N6M 1L8	5496	Not Available	Not Available	No	549428.9	3428.1		5405.9	0.98	272.2	187.7	34.2	
Tavistock PS	School	79 Maria St	TAVISTOCK	N0B2R0	3951	60	0	No	163617.9	1470.9		2059.9	0.52	144.4	78.5	19.9	
Tecumseh PS	School	401 Tecumseh AVE E	LONDON	N6C1T4	4162	60	0	No	116471.8	2342.2		2761.5	0.66	183.3	121	29.1	
Thamesford PS	School	130 McCarty St	THAMESFORD	N0M2M0	3130	60	3	No	208091.2	1182.9		1932	0.62	172.2	65.3	20.9	
Tollgate Central FI PS	School	744993 OXFORD ROAD 17 RR 6	WOODSTOCK	N4S7W1	1313	0	0	No	52063.5	1311.2		1498.6	1.15	319.4	67.4	51.6	Closed
Trafalgar PS	School	919 Trafalgar ST	LONDON	N5Z1G3	4099	60	0	No	98719.2	1736.7		2092.1	0.51	141.7	90.1	22	
Tweedsmuir PS	School	349 Tweedsmuir AVE	LONDON	N5W1L5	3951.9	65	0	No	222872.9	1940		2742.3	0.68	188.9	103.8	25.9	
University Heights PS	School	27 Ford CRES	LONDON	N6G1H8	3135.9	60	1	No	251881.8	847.5		1754.2	0.56	155.6	49.7	15.8	
Valleyview Central PS	School	10339 Ilderton RD	ILDERTON	N0M2A0	1891	60	0	No	75117.7	697.4		967.8	0.51	141.7	37.2	19.7	
Vansittart Woods Env. Ed Centre	School	Blanford Road at Township Road 3, RR 5	WOODSTOCK	N4S7V9	419.9	40	0	No	26822.5	Not Available	238.7	335.2	0.8	222.2	15.3	36.6	
Victoria PS	School	130 Wharncliffe RD S	LONDON	N6J2K5	4099.4	60	0	No	193750.5	1623.4		2320.8	0.57	158.3	87	21.2	
W. Sherwood Fox PS	School	660 Steeplechase DR	LONDON	N6J3P4	5751	65	4	No	516540.8	1538.9		3398.3	0.6	166.7	91.8	16.2	
West Elgin Sr PS	School	145 Graham ST	WEST LORNE	N0L2P0	3269.9	60	0	No	201447.9	1011.3		1736.5	0.53	147.2	56.5	17.3	
West Elgin SS	School	139 Graham ST	WEST LORNE	N0L2P0	8894	60	0	No	581280.7	5448		7540.5	0.85	236.1	290.2	32.6	

Property Name	Operation	Address	City	Postal Code	Gross Floor Area(M ²)	Weekly Average Hours	Number of Portables	Swimming pool	Electricity Use - Grid Purchase (kWh)	Natural Gas Use (GJ)	Propane Use (GJ)	Site Energy Use (GJ)	Site EUI (GJ/m ²)	Site EUI (EkWh/m ²)	Total (Location-Based) GHG Emissions (Metric Tons CO2e)	Total (Location-Based) GHG Emissions Intensity (kgCO2e/m ²)	Comments
West Nissouri PS	School	37 Elliott TRAIL RR 1	THORNDALE	N0M2P0	4089.4	60	5	No	327496.3	1380		2558.9	0.64	177.8	78.6	19.6	
West Oaks FI PS	School	1050 Plantation RD	LONDON	N6H2Y5	4832	60	1	No	285990.2	929.1		1958.6	0.41	113.9	54.7	11.3	
Westfield PS	School	102 Dereham Dr	TILLSONBURG	N4G0G5	5391.3	60	3	No	331035.1	1425.4		2617.1	0.49	136.1	80.9	15	
Westminster Central PS	School	2835 Westminster DR	LONDON	N6N1L7	2612	0	0	No	38468.8	962.9		1101.4	0.42	116.7	49.5	19	Closed
Westminster SS	School	230 Base line RD W	LONDON	N6J1W1	14391	60	0	No	768640.8	3261.8		6028.8	0.42	116.7	185.5	12.9	
Westmount PS	School	1011 Viscount RD	LONDON	N6K1H5	6017.8	60	0	No	424505.1	1624.3		3152.5	0.54	150.0	93.6	15.9	
White Oaks PS	School	565 Bradley AVE	LONDON	N6E3Z8	13439.1	72	8	Yes	1734608.8	8779.9		15024.2	1.11	308.3	490	36.3	
Wilberforce PS	School	340 Beech ST	LUCAN	N0M2J0	4909.6	60	8	No	457333.9	1001.4		2647.7	0.54	150.0	63.2	12.9	
Wilfrid Jury PS	School	950 Lawson RD	LONDON	N6G3M2	8516	65	4	No	901566.2	1881.7		5127.2	0.6	166.7	119.8	14	
Wilton Grove PS	School	626 Osgoode DR	LONDON	N6E1C1	5083.9	65	0	No	316701.1	1929.4		3069.5	0.6	166.7	105.9	20.8	
Winchester Street PS	School	110 WINCHESTER ST	WOODSTOCK	N4S7K5	4272.3	60	0	No	273946.9	1256.9		2243	0.52	144.4	70.9	16.3	
Woodland Heights PS	School	474 Springbank DR	LONDON	N6J1G8	5451.9	60	0	No	313855.2	2710.1		3839.9	0.7	194.4	145	26.6	
Woodstock CI	School	35 Riddell ST	WOODSTOCK	N4S6L9	8851	60	0	No	445514.8	4443.5		6047.3	0.68	188.9	235.9	26.7	
Wortley Road PS	School	301 Wortley RD	LONDON	N6C3R6	3498.9	60	0	No	161322.6	1031.8		1612.5	0.47	130.6	56.4	16.5	